



BRANZ Appraised
Appraisal No. 648 [2016]
**KNAUF GLASSWOOL
INSULATION**



Appraisal No. 648 [2016]
Amended 12 May 2021

BRANZ Appraisals

Technical Assessments of
products for building and
construction.



**Knauf Insulation Pty
Limited**

Unit 1/44 Borthwick Avenue
Murarrie
Queensland 4172
Australia
Tel: + 61 7 3343 1989
Web: www.knaufinsulation.com.au



BRANZ

BRANZ

1222 Moonshine Rd,
RD1, Porirua 5381
Private Bag 50 908
Porirua 5240,
New Zealand
Tel: 04 237 1170
branz.co.nz



Product

- 1.1 Knauf Glasswool Insulation is a range of thermal insulating material manufactured from ECOSE® Technology resin-bonded, glass wool fibres. The insulation is pre-cut to suit a wide range of thermal insulation requirements and framing set-outs in walls, ceilings and roofs of buildings.
- 1.2 The Knauf Glasswool Insulation product range includes Earthwool® Glasswool Insulation and Earthwool® Glasswool Insulation with DriTherm® Technology products, as detailed in Table 1. Earthwool® Glasswool Insulation with DriTherm® Technology is silicon treated.

Scope

- 2.1 Knauf Glasswool Insulation has been appraised as a thermal insulating material for framed or part-framed walls, ceilings and roofs of domestic and commercial buildings.

Building Regulations

New Zealand Building Code (NZBC)

- 3.1 In the opinion of BRANZ, Knauf Glasswool Insulation, if designed, used, installed and maintained in accordance with the statements and conditions of this Appraisal, will meet or contribute to meeting the following provisions of the NZBC:

Clause B2 DURABILITY: Performance B2.3.1 (a) not less than 50 years and B2.3.1 (b) 15 years and B2.3.2. Knauf Glasswool Insulation meets these requirements. See Paragraph 8.1.

Clause E3 INTERNAL MOISTURE: Performance E3.3.1. Knauf Glasswool Insulation contributes to meeting this requirement. See Paragraphs 13.1 and 13.2.

Clause F2 HAZARDOUS BUILDING MATERIALS: Performance F2.3.1. Knauf Glasswool Insulation meets this requirement.

Clause H1 ENERGY EFFICIENCY: Performance H1.3.1 (a) and H1.3.2 E. Knauf Glasswool Insulation contributes to meeting these requirements. See Paragraphs 14.1 and 14.2.

Technical Specification

4.1 Knauf Glasswool Insulation is an ECOSE® Technology resin-bonded, fibrous glass wool insulation manufactured from recycled and/or virgin glass and ECOSE® Technology resin. Earthwool® Glasswool Insulation with DriTherm® Technology is silicon treated. Knauf Glasswool Insulation are formed into segments, blankets and rolls and are available as set out in Table 1.

Table 1: Knauf Glasswool Insulation product ranges

R-value	Nominal Thickness [mm]	Width [mm]	Length [mm]	Density [kg/m ³]
Earthwool® Glasswool Insulation - Acoustic Range				
1.3	50	600	2,700	11.0
1.4	50	430, 450, 580 or 600	1,160	14.0
1.9	75	600	2,700	11.0
2.0	75	430, 450, 580 or 600	1160	14.0
Earthwool® Glasswool Insulation - Wall Segments				
2.2	90	580	1,160	10.8
2.4	90	580	1,160	14.5
2.6	90	430 or 580	1,160	20.3
2.8	90	430 or 580	1,160	29.1
3.2	140	580	1,160	9.3
3.6	140	580	1,160	13.4
4.1	140	580	1,160	21.0
Earthwool® Glasswool Insulation with DriTherm® Technology - Wall Segments				
2.2	90	580	1,160	10.7
2.4	90	580	1,160	14.6
Earthwool® Glasswool Insulation - Ceiling Segments				
2.7	125	430	1,160	8.8
3.2	150	430	1,160	8.7
3.2*	105	430	1,160	23.3
3.6	175	430 or 600	1,160	7.3
4.1	195	430	1,160	7.7
5.2	210	430	1,160	11.2
6.3	275	430	1,160	9.0
Earthwool® Glasswool Insulation with DriTherm® Technology - Ceiling Segments				
R3.6	175	430 or 600	1200	7.4
R5.2	210	430	1160	11.4
R6.3	275	430	1160	9.0
Earthwool® Glasswool Insulation - Ceiling Rolls				
1.8	70	1,200	13,500	12.1
2.9	115	1,200	8,500	12.2
3.2	135	1,200	8,000	11.0
3.6	150	1,200	7,000	11.0

Earthwool® Glasswool Insulation - Handy Rolls				
2.2	90	430 or 580	18,000	10.7
Earthwool® Glasswool Insulation with DriTherm® Technology - Handy Rolls				
2.2	90	430 or 580	18,000	10.8
Earthwool® Glasswool Insulation - Masonry Wall Insulation				
1.5	50	600	1,100	29.5
Earthwool® Glasswool Insulation - Commercial Rolls				
1.4	55	1,200	37,000	11.1
1.6	60	1,200	28,000	13.4
1.9	75	1,200	26,000	11.6
2.4	100	1,200	22,000	10.2
2.6	105	1,200	18,500	11.5
3.1	120	1,200	14,500	13.1
3.3	130	1,200	13,500	12.7
Earthwool Glasswool with Dritherm® Technology - SoundShield				
R2.6	90	430 or 580	1,160	20.07
Knauf Insulation with Dritherm Technology - Smart Facade				
R1.6	50	600	1,200	38.0
R2.2	75	600	1,200	38.0
R3.2	100	600	1,200	38.0

Note: * Skillion Roof

- 4.2 Knauf Glasswool Insulation is brown in colour and is packaged in pre-printed plastic compression bags with labelling in compliance with AS/NZS 4859.1.
- 4.3 Accessories used with Knauf Glasswool Insulation, which are supplied by the insulation installer, are plastic strapping and fixings.

Handling and Storage

- 5.1 Knauf Glasswool Insulation must be stored under cover and in dry conditions. Heavy objects must not be stacked on the packs. The packs must be stored in an orientation that avoids excessive compression of the product.
- 5.2 In general, insulation products are sensitive to the length of time they are stored under compression packaging. Product that does not recover to its nominal thickness may not achieve the stated thermal resistance [R-value].

Technical Literature

- 6.1 Refer to the Appraisal listing on the BRANZ website for details of the current Technical Literature for Knauf Glasswool Insulation. The Technical Literature must be read in conjunction with this Appraisal. All aspects of design, use, installation and maintenance contained in the Technical Literature and within the scope of this Appraisal must be followed.

Design Information

General

- 7.1 Knauf Glasswool Insulation is intended for use as thermal insulation to meet the requirements of the NZBC. Knauf Glasswool Insulation can be used to meet the minimum schedule method R-values of NZBC Verification Method H1/VM1 or NZBC Acceptable Solution H1/AS1. Greater construction R-values can be achieved where specific design is used. For construction R-values, refer to the BRANZ House Insulation Guide. Product R-values and dimensions are given in Table 1.
- 7.2 Knauf Glasswool Insulation's R-values have been determined by testing to AS/NZS 4859.1, which is an acceptable method in NZBC Acceptable Solution H1/AS1.
- 7.3 Knauf Glasswool Insulation segment, blanket and roll products are designed to be friction-fitted between wall, ceiling or roof framing. They can also be laid directly on a ceiling lining, or over ceiling battens or joist/truss chords. In other horizontal situations, the insulation must be adequately supported by a suitable durable material. Earthwool® glasswool skillion roof insulation is designed to be friction-fitted between rafters.
- 7.4 Where the insulation is installed in exterior walls, the insulation material nominal thickness must be selected to provide a snug close fit which touches all sides of the insulation cavity between the wall underlay and the interior wall lining.
- 7.5 Where the insulation is retrofitted in external timber-framed walls without a wall underlay, and with direct-fixed claddings, the insulation must be at least 20 mm thinner than the framing to allow a gap of at least 20 mm between the insulation and the wall cladding. Horizontal straps must be stapled into the sides of the wall studs at 300 mm centres maximum as support before the insulation is installed. Refer also to NZS 4246, Section 5.4.2.
- 7.6 When the insulation is installed in a wall with a drained cavity, it is recommended that specific wall products with a controlled nominal thickness be used. Where the stud spacings are greater than 450 mm, an intermediate means of restraining the insulation from bulging into the cavity must be installed in accordance with NZBC Acceptable Solution E2/AS1, Paragraph 9.1.8.5.
- 7.7 To prevent moisture transfer and to provide roof ventilation, a separation of 25 mm minimum is required between the insulation and any rigid substrate or flexible roof underlay. Selecting the specifically designed skillion roof insulation product with a controlled thickness can assist with this requirement.
- 7.8 The building envelope must be constructed to ensure the insulation remains dry during installation and throughout the life of the building.
- 7.9 The clearance requirements for heating appliances and downlights must be met and reference made to the manufacturers instructions and NZS 4246. See Paragraphs 10.1-10.3.

Durability

- 8.1 The durability assessment of Knauf Glasswool Insulation to meet the requirements of the NZBC is based on the difficulty of access and replacement, and the ability to detect failure of the insulation, both during normal use and maintenance of the building.

Serviceable Life

- 8.2 Where the building is maintained so that the provisions of the NZBC E2 and E3 Clauses are met, and where the insulation is not crushed or exposed to conditions that will diminish its thermal performance, Knauf Glasswool Insulation can expect to have a serviceable life of at least 50 years.

Maintenance

- 9.1 Knauf Glasswool Insulation that has become damp must be removed and the cause of dampness repaired. Cavities must be clean and dry before fitting new insulation of an equivalent thermal rating. NZS 4246 gives guidance on thermal insulation maintenance due to water damage.
- 9.2 Earthwool® Glasswool Insulation with DriTherm® Technology may be dried and retrofitted into the dried cavity if the cause of dampness was a potable water leak. NZS 4246 gives guidance on thermal insulation maintenance due to water damage.

Prevention of Fire Occurring

- 10.1 Knauf Glasswool Insulation is considered a non-combustible material and need not be separated from heat sources such as fireplaces, flues and chimneys. However, when used in conjunction with or attached to heat sensitive materials, the heat sensitive material must be separated or protected from heat sources. Part 7 of NZBC Verification Method C/VM1 and Acceptable Solution C/AS1, and NZBC Acceptable Solution C/AS2 provide methods for separation and protection of combustible materials from heat sources.

Downlights

- 10.2 Recessed luminaires shall be of the specified luminaire types and installed in accordance with NZBC Verification Method C/VM1 and NZBC Acceptable Solution C/AS1, Section 7.4.
- 10.3 Insulation materials must maintain a clearance of 100 mm to undefined recessed luminaires in existing buildings.

Fire Affecting Areas Beyond the Fire Source

- 11.1 Knauf Glasswool Insulation has a Group Number of 1-S. When used in an occupied space, Knauf Glasswool Insulation may or may not need to be enclosed by an internal lining depending on the Risk Group. Refer to the relevant NZBC Acceptable Solutions C/AS1 and C/AS2 for specific internal surface finish requirements.

External Moisture

- 12.1 The total building envelope must be weathertight and comply with the requirements of NZBC Clause E2 to ensure that the insulation remains dry in use.
- 12.2 The moisture content of the construction materials at the time of installing and enclosing the insulation must meet the requirements of NZBC Acceptable Solution E2/AS1, Paragraph 10.2 a) or lower moisture content if required by the lining manufacturer.

Internal Moisture

- 13.1 Buildings must provide an adequate combination of thermal resistance, ventilation and space temperature to all habitable spaces, bathrooms, laundries and other spaces where moisture may be generated or may accumulate. This does not apply to communal non-residential, commercial, industrial outbuildings or ancillary buildings.
- 13.2 Roofs and walls of housing complying with the Schedule Method for Compliance with Clause H1.3.2 E will have adequate thermal resistance. Other buildings may require more thermal insulation to satisfy the requirements of NZBC Acceptable Solution E3/AS1 than that to satisfy the energy efficiency provisions alone.

Energy Efficiency

- 14.1 Knauf Glasswool Insulation will contribute to meeting the requirements of NZBC Clause H1 Performance H1.3.1 [a] and H1.3.2 E by compliance with NZBC Verification Method H1/VM1 or NZBC Acceptable Solution H1/AS1. Refer to Paragraphs 7.1-7.7.
- 14.2 Knauf Glasswool Insulation R-values have been determined by BRANZ testing to AS/NZS 4859.1 and are given in Table 1.

Installation Information

Installation Skill Level Requirements

- 15.1 All design and building work must be carried out in accordance with the Knauf Glasswool Insulation Technical Literature and this Appraisal. All building work must be undertaken by competent and experienced tradespersons conversant with Knauf Glasswool Insulation.

General

- 16.1 Installation of Knauf Glasswool Insulation must be in accordance with the Technical Literature and this Appraisal. NZS 4246 should be used as a guide for installing insulation in residential buildings.
- 16.2 The product must be installed only when the building is enclosed and when the construction materials have achieved the required maximum moisture content or less.
- 16.3 Knauf Glasswool Insulation must be released from the packaging and allowed to re-loft prior to installation. The time to loft will depend upon the length of time the product has been packaged and stored.
- 16.4 Knauf Glasswool Insulation is supplied in segments, blanket and roll form [Table 1] to suit framing layouts. The segment products are sized to fit between standard framing centres. The products are able to be cut to suit wall cavities and when fitted between roof or ceiling framing. The insulation must be neatly friction-fitted between framing members so that the potential for gaps and convective heat loss is reduced. In wall cavities the insulation must be neatly friction-fitted between framing members to prevent sagging. In ceilings or roofs, the insulation may be fitted between framing members or fitted over framing members and butted tightly. The insulation must extend to the external wall plate. The insulation must not be folded, tucked or compressed. A close, even fit provides the most efficient thermal performance. Whenever possible, the insulation should be fitted beneath wiring or plumbing.
- 16.5 The clearance requirements for heating appliances, light fittings and downlights must be followed. Refer also to NZS 4246.

Inspections

- 16.6 The Technical Literature, this Appraisal and NZS 4246 must be referred to during the inspection of Knauf Glasswool Insulation installations.

Health and Safety

- 17.1 Refer to the Technical Literature and NZS 4246 for guidance on health and safety requirements such as personal protective clothing and installation hazard assessment.

Basis of Appraisal

The following is a summary of the technical investigation carried out:

Tests

- 18.1 BRANZ has carried out thermal resistance testing of Knauf Glasswool Insulation in accordance with AS/NZS 4859.1.
- 18.2 Tests have been carried out in accordance with AS 1530.1. Knauf Glasswool Insulation is not deemed combustible according to the test criteria. The results have been reviewed by BRANZ technical experts.

Other Investigations

- 19.1 An assessment of the durability of Knauf Glasswool Insulation has been made by BRANZ technical experts.
- 19.2 The manufacturer's Technical Literature have been reviewed by BRANZ and found to be satisfactory.
- 19.3 The fibre used to manufacture Knauf Glasswool Insulation is certified to the European Certification Board for Mineral Wool Products [EUCEB].



Quality

- 20.1 The manufacture of Knauf Glasswool Insulation has been examined by BRANZ, including methods adopted for quality control. Details of the manufacturing processes, and quality and composition of the raw materials used were obtained and found to be satisfactory.
- 20.2 Knauf Insulation Pty Limited is responsible for the quality of the product supplied.
- 20.3 Quality of installation of the product on-site is the responsibility of the installer.
- 20.4 Quality of maintenance of the building to ensure the insulation remains dry is the responsibility of the building owner.

Sources of Information

- AS 1530.1: 1994 Combustibility test for materials.
- AS/NZS 4859.1: 2002 Materials for the thermal insulation of buildings.
- AS/NZS 4859.1: 2018 Thermal insulation materials for buildings - Part 1: General criteria and technical provisions.
- BRANZ House Insulation Guide, Fifth Edition 2014.
- BRANZ Bulletin Number 525 Preventing moisture problems in timber-framed skillion roofs.
- NZS 4214: 2006 Method of determining the total thermal resistance of parts of buildings.
- NZS 4246: 2016 Energy efficiency - Installing bulk thermal insulation in residential buildings.
- Ministry of Business, Innovation and Employment Records of Amendments for Compliance Documents and Handbooks.
- The Building Regulations 1992.

Amendments

Amendment No. 1, dated 12 May 2021.

This Appraisal has been amended to update the Appraisal name, and to include Earthwool® Glasswool Insulation with DriTherm® Technology products. The Appraisal text and product range in Table 1 have also been updated.



BRANZ Appraised
Appraisal No. 648 [2016]

BRANZ Appraisal
Appraisal No. 648 [2016]
01 December 2016

KNAUF GLASSWOOL INSULATION



In the opinion of BRANZ, **Knauf Glasswool Insulation** is fit for purpose and will comply with the Building Code to the extent specified in this Appraisal provided it is used, designed, installed and maintained as set out in this Appraisal.

The Appraisal is issued only to **Knauf Insulation Pty Ltd**, and is valid until further notice, subject to the Conditions of Appraisal.

Conditions of Appraisal

1. This Appraisal:
 - a) relates only to the product as described herein;
 - b) must be read, considered and used in full together with the Technical Literature;
 - c) does not address any Legislation, Regulations, Codes or Standards, not specifically named herein;
 - d) is copyright of BRANZ.
2. **Knauf Insulation Pty Ltd**:
 - a) continues to have the product reviewed by BRANZ;
 - b) shall notify BRANZ of any changes in product specification or quality assurance measures prior to the product being marketed;
 - c) abides by the BRANZ Appraisals Services Terms and Conditions;
 - d) warrants that the product and the manufacturing process for the product are maintained at or above the standards, levels and quality assessed and found satisfactory by BRANZ pursuant to BRANZ's Appraisal of the product.
3. BRANZ makes no representation or warranty as to:
 - a) the nature of individual examples of, batches of, or individual installations of the product, including methods and workmanship;
 - b) the presence or absence of any patent or similar rights subsisting in the product or any other product;
 - c) any guarantee or warranty offered by **Knauf Insulation Pty Ltd**.
4. Any reference in this Appraisal to any other publication shall be read as a reference to the version of the publication specified in this Appraisal.
5. BRANZ provides no certification, guarantee, indemnity or warranty, to **Knauf Insulation Pty Ltd** or any third party.

For BRANZ

Chelydra Percy

Chief Executive

Date of Issue:

01 December 2016